

Mfg./Mkted. all types of Fire Extinguishers, Fire Fighting, CCTV Equipment, Spl. in Refilling & Maintenance Contractor

RH-2, Sarvodaya Res, Opp. Copa Villa Restaurant, Jagtap Dairy, PCMC Pune (M.H.) - 411027  
Mobile : 75664-99966, 77, 88 Ph : 020-48649966

Email: [sales@firenet.co.in](mailto:sales@firenet.co.in), [support@firenet.co.in](mailto:support@firenet.co.in)  
Web: [www.firenet.co.in](http://www.firenet.co.in) / [www.firenetindia101.com](http://www.firenetindia101.com)

## CERTIFICATE

This is to certify that we had carried out complete inspected internally and externally to Fire Extinguisher and certificate issue to: -

**M/s. D.A.V. Public School**

**Address: 157, DP Rd, Raagdari Society, Aundh, Pune, Maharashtra 411007**

### Testing & Inspection Report of fire Extinguisher

<b>Year of Contract</b>	2022-2023	Date- 2/11/2022
<b>Certificate No.</b>	FNT/IND/22-23/PUNE/000111	
<b>Completion Month</b>	NOV 2022	
<b>Valid Up to</b>	NOV 2023	
<b>Warranty for</b>	01-Years	
<b>Details of Refilling Extinguisher</b>	ABC Type Capacity – 2 Kgs. CO2 Type Capacity – 4.5 Kgs. DCP Type Capacity – 10 Kgs. DCP Type Capacity – 5 Kgs. WATER Type Capacity – 9 Later.	04 Nos. 15 Nos. 11 Nos. 05 Nos. 12 Nos
<b>Inspection Details Of fire Extinguisher</b>	<ol style="list-style-type: none"> <li>1. Check for proper sizes, types, quantity and placement of fire extinguishers. Ensure that each fire extinguisher is properly mounted, conspicuously located, not obstructed by objects and readily available for use in case of a fire.</li> <li>2. Make sure the instruction label is legible and facing outward.</li> <li>3. Check to be sure the extinguisher is fully pressurized, and/or at its full charged weight. Make sure the fire extinguisher hose is intact and free from obstruction.</li> <li>4. Operate the pull pin or locking device and install a new tamper seal. Check for dents, corrosion, other signs of damage.</li> <li>5. Look for any modifications to the fire extinguisher that could possibly reduce its functionality.</li> <li>6. Verify that the extinguisher is current on all internal maintenance and pressure testing requirements.</li> <li>7. Attach an updated tag or label as a record of proper maintenance.</li> </ol>	
<b>Declaration</b>	We further certify that ( <b>FIRENET</b> ) has successfully checked above fire extinguisher which is in good & working condition but necessary periodical maintenance, services and refill when required to fire extinguisher will be done by us.	



**Signature of the inspector**